

## Trained Crowd Manager

Any user of indoor District facilities (excluding churches) where fifty (50) people or more will be present in any one room must have trained crowd managers present and comply with the crowd management requirements of the Florida Fire Prevention Code ("FFPC") Section 101-12.7.6. Where the occupant load exceeds 250, in any one room additional trained crowd managers shall be provided at a ratio of one (1) crowd manager for every 250 occupants. A user may become a trained crowd manager by contacting the fire department and making arrangements for training and certification. NOTE: An opinion issued by the Florida State Fire Marshall's office eliminated the need for crowd managers at outside events.

**Requirements:**

<b>50 – 250 persons:</b>	<b>1 Crowd Manager</b>
<b>251 – 500 persons:</b>	<b>2 Crowd Managers</b>
<b>Every 250 additional persons:</b>	<b>1 more Crowd Manager</b>

Those users required to have a trained crowd manager may obtain the training from any of the fire departments listed below. A certification of completion must be submitted with the lease.

### Fire Control Districts

**North Collier Fire Department**

Captain Robert Berman  
1885 Veterans Park Drive  
Naples, FL. 34109  
Phone: (239) 597-3222  
Fax: (239) 597-7082  
[E-mail: rberman@northcollierfire.com](mailto:rberman@northcollierfire.com)

**City of Naples Fire Department**

Inspector Tina Young  
355 Riverside Circle  
Naples, FL. 34102  
Fax: (239) 213-4907  
E-Mail: [tyoung@naplesgov.com](mailto:tyoung@naplesgov.com)

**Greater Naples Fire Department**

Inspector Mike Cruz  
2770 Horseshoe Drive  
Naples, FL. 34104  
Phone: (239) 774-2800  
Fax: (239) 774-3116  
[E-mail: fls@gnfire.org](mailto:fls@gnfire.org)

**Marco Island Fire Department**

Inspector Ray Munyon  
1280 San Marco Rd  
Marco Island, FL. 34145  
Phone: (239) 394-5405  
[E-mail: rmunyon@CityofMarcoIsland.com](mailto:rmunyon@CityofMarcoIsland.com)

Those users not required to have a trained crowd manager present must complete a Crowd Manager Waiver Form (F2) attesting that the number of people present will be less than the requirements of FFPC.